



**GT2150 MANUAL SLIDING DOOR
FLOOR TRACK MODEL
Suggested Architectural Specifications
Section 8**

**Series GT2150
MANUAL ICU / CCU Sliding Door
FLOOR TRACK - FULL BREAKAWAY**

**Division 08 - Openings
Section 08 42 43 - INTENSIVE CARE UNIT / CRITICAL CARE UNIT ENTRANCES**

Note to Specifier: Articles and paragraphs below may be edited or modified to suit specific project requirements.

Add section numbers and titles per CSI "MasterFormat" and specifier's standard practice. Contact manufacturer's representative to discuss specification modifications, performance requirements, accessories and/or related equipment that may be applicable to this project.

Part 1 - GENERAL

1.01 DESCRIPTION

- A. Furnish and install manual slide door equipment as indicated on drawings and specifications.
- B. Related work specified elsewhere.
 - 1. Concrete: Division 03, applicable sections.
 - 2. Masonry: Division 04, applicable sections.
 - 3. Thermal and Moisture Protection: Division 07, applicable sections.
 - 4. Openings: Division 08, applicable sections.
 - 5. Electrical Grounding 16, applicable sections.

1.02 REFERENCES

- A. American Architectural Manufacturers Association (AAMA) - www.aamanet.org
- B. American National Standards Institute (ANSI) - www.ansi.org
- C. Builders' Hardware Manufacturers Association (BHMA) - www.buildershardware.com
- D. National Fire Protection Association (NFPA) - www.nfpa.org
- E. International Code Council (ICC) - www.iccsafe.org or Applicable State and Local Codes

1.03 QUALITY ASSURANCE

- A. Manufacturer's Qualifications: Manufacturer to have at least (5) five years of experience in the fabrication of automatic and manual entrance systems.
- B. Installer's Qualifications: Products specified shall be represented by a factory authorized and trained distributor. Distributor shall be AAADM Certified, maintain a parts inventory and have trained service personnel with experience installing and maintaining units indicated for this project.

1.04 SUBMITTALS

- A. Product Data: Submit manufacturer's product and complete installation data for all materials covered in this section.
- B. Shop Drawings: Submit complete elevations, details and methods of anchorage to location; installation of hardware; size, shape, joints and connections; and details of joining with other construction.
- C. Templates and Diagrams: As needed shall be furnished to fabricators and installers of related work for coordination of door system installation with concrete work, masonry, and other related work.
- D. A copy of appropriate manual shall be provided to owner / contractor upon completion of installation.

1.05 SUBSTITUTIONS

- A. Equipment as manufactured by NABCO Entrances, Inc. has been specified and shall be quoted as the base bid. Proposals for substitution products may be submitted by the bidding contractors a minimum of 10 days prior to bid due date. The proposed substitution shall meet the quality and performance standards described in this specification.



**GT2150 MANUAL SLIDING DOOR
FLOOR TRACK MODEL
Suggested Architectural Specifications
Section 8**

1.06 JOB SITE CONDITIONS

- A. Site Survey: Verify site conditions including, but not limited to the following; opening sizes, floor conditions, plumb and level mounting surfaces (substrates shall be of proper dimension and material).
- B. Coordinate installation with glass, glazing, hardware and other trades to avoid construction delays.

1.07 WARRANTY

- A. Warranted materials shall be free of defects in material and workmanship for a period of one year from date of substantial completion. During the warranty period the Owner shall request NABCO factory-trained technicians to perform service. Warranty repairs are provided during normal business hours. Owner to receive warranty after completion of installation.

PART 2-PRODUCTS

2.01 APPROVED MANUFACTURER

- A. All door equipment shall be manufactured by:
 - NABCO Entrances Inc.
 - 582 W18717 Gemini Drive
 - Muskego, WI 53150
 - Phone: (877) 622-2694
 - Fax: (888) 679-3319
 - Email: info@nabcoentrances.com

2.02 MANUAL SLIDING DOOR SYSTEM

NABCO GT2125 ICU/CCU Sliding Door System

- A. Mode of operation: The NABCO Series 2150 provides room access with a floor track in the sidelite area. The floor track design allows for surface mounting or recess mounted applications. Under normal operating conditions, medical personnel have access by way of the sliding door. When patient and/or medical equipment access is required, the swing panel(s) shall swing out and allow for sliding door(s) to breakaway to the full-open position. The floor track allows the door panels to breakaway in any position of door travel. Doors and swing panels in the full breakaway position double the NORMAL entrance opening. Reset procedures occur in reverse order.
- B. Types / Configurations:
 - a. Single, SO-SX or SX-SO and SO-SX-SO
 - b. Bi-part, SO-SX-SX-SO
- C. Product Components:
 - 1. Aluminum doors, fixed panels and frame assembly.
 - 2. Rollers – Support and Guide
 - 3. Door carrier hanger assembly, fixed panel, breakaway latches, limiting arms, pull handles, static arrester, and weathering seal

1a) Door panel(s) and Swing panel(s) shall be factory assembled with 3/8-16 threaded tie rods spanning full length of top and bottom rails. Snap in glass stop with integral extruded vinyl standoff to accommodate glass flexing. A horizontal muntin bar to provide glass protection. Configurations shall include a 2 panel (single), 3 panel (single, center panel slides) and 4 panel (bi-part) versions.

1b) Vertical Jambs shall be 1-3/4 x 4-1/2" (44mm x 114mm) and Horizontal Header shall be 5" by 4-1/2" (127mm x 114mm). The header includes a door track and anti-riser guide. Header shall be accessible by a hinged cover that locks in the open position for ease of service.

1c) Surface or recess mounted extruded guide track shall be installed in line with the door panel (SX) and shall not extend beyond the swing panel (SO).

1d) All major extrusions to be minimum 1/8" (3mm) wall thickness.

1e) All extruded aluminum sections shall be 6063-T5 or equivalent.



**GT2150 MANUAL SLIDING DOOR
FLOOR TRACK MODEL
Suggested Architectural Specifications
Section 8**

1f) Finish: Aluminum shall have a standard finish of AA-M12-C22-A31 (204 R1) or AA-M12-C22-A44 (dark bronze). Black and special finishes available upon request.

2) Sliding door shall ride on two steel, urethane coated support rollers incorporating lubricated sealed ball bearings, and two equivalent anti-rise rollers. Each roller assembly shall have a $\pm 7/16$ " (11mm) of vertical adjustment. Each swing panel shall include one bottom guide assembly. Guide blocks shall be attached to the swing panel with a 3/16" (5mm) thick formed guide bracket. All steel brackets and fittings shall be plated for corrosion resistance.

3a) Entrance systems shall have door panels attached to a door carrier hanger assembly by means of an adjustable support rod pivot assembly and corrosion resistant adjustable breakaway release latch holding the door panel in the closed position under normal manual operation. The support rod pivot assembly allows the door to swing freely in panic mode without sagging. The system shall have breakaway swing panels held in place by means of a top and bottom pivot and a corrosion resistant adjustable breakaway release latch for holding the panel in the closed position. Breakaway pressure shall be field adjustable (5-50 lbs.) to meet local building code requirements but will be factory set at 50 lbs. maximum.

3b) A limiting arm to control the panels as they swing in the direction of egress.

3c) Door pull adjacent to swing panel is of recessed type to preclude pinch point. "D" shaped pull extending from leading edge of stile provides external door activation.

3d) An electrical grounding system on each door grounds entrance package from static electricity.

3e) 1/2" wide vinyl fin positioned between the door(s) and lead stile(s) of the swing panel(s).

3f) Optional positive latch and additional air infiltration seals available upon request.

PART 3-EXECUTION

3.01 INSTALLATION

- A. Door equipment shall be installed by manufacturer-approved, factory-trained installers in compliance with manufacturer's recommendations and approved shop drawings.

3.02 CLEANING AND PROTECTION

- A. After installation, clean framing members as recommended by manufacturer. Aluminum surfaces in contact with masonry, concrete, or steel shall be protected from contact by use of neoprene gaskets where indicated or a coat of bituminous paint to prevent galvanic or corrosive action. Advise general contractor to protect unit from damage during subsequent construction activities.

***COVER NOTE TO SPECIFICATION WRITER**

- A. Preparation of a plumb and square opening to receive sliding door equipment with adequate support.
- B. Glass and glazing shall be described in glazing section of the specifications, door to be glazed square.
- C. CONCRETE INSTALLER shall prepare floor at location of entrance system to be level and smooth without changes in elevation between foundation and associated walkways.

END OF SECTION